

# SUBMITTAL TRANSMITTAL

CONTRACTOR'S REVIEW STAMP


A/E REVIEW STAMP

**DENCO CONSTRUCTION SPECIALISTS  
SHOP DRAWING AND SUBMITTAL REVIEW**

JOB NO. DPA-032000  
DATE 3-4-19  
REVIEWER Shawnee Hallmark

Corrections or comments made relative to submittals during this review do not relieve the subcontractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The subcontractor is responsible for conforming and correlating all quantities and dimensions, selecting fabrication processes and techniques of construction, coordinating his work with that of other trades and performing his work in a safe and satisfactory manner.

**THIS REVIEW DOES NOT INDICATE NOR IMPLY ANY APPROVAL  
OF CHANGES TO TIME OR CHANGES IN COSTS**



**SUBMITTAL DATA**

Project Dallas Park & Rec Dept Admin Offices Location 10031 E. Northwest Highway Dallas, TX 75238

General Contractor DENCO CONSTRUCTION SPECIALISTS

Trade Concrete

Items Submitted Rebar for Masonry

Supplier Accurate Masonry Phone 817-838-7192

Substitutions and Deviations \_\_\_\_\_

Remarks \_\_\_\_\_

I CERTIFY THAT THE ABOVE ITEM DESCRIBED IN THE ATTACHED SUBMITTAL COMPLIES WITH THE CONTRACT DOCUMENTS EXCEPT AS NOTED ABOVE.

Shawnee Hallmark 972-226-2609 ext. 108 3-4-19

NAME (TRADE)	PHONE NO.	DATE
--------------	-----------	------

Review Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



P.O. Box 14786  
Fort Worth, TX 76117  
Phone: 817-838-7192  
Fax: 817-838-749

## SUBMITTAL # 4

## Rebar

PROJECT – DPARD Administrative Offices

### Job Information:

**Architect:** Perkins and Will  
10100 North Central Expressway  
Dallas, Texas 75231

**Project Manager:** David Shaulis  
**General Contractor:** Denco Construction Specialists  
5525 Lyons Road  
Garland, TX 75043

**(Sub)Sub Contractor:** N/A

### Item Information:

**Item Submitted:** Rebar

**Attachment:** Manufacturer Certification Letter

**Spec. Section:** n/a

**Drawing No.:** N/A

**Supplier:** Concrete Related Products  
PO Box 436  
Cleburne, TX 76033  
**P: 817.558.6999**

**Manufacturers:** Concrete Related Products  
PO Box 436  
Cleburne, TX 76033  
**P: 817.558.6999**

**Application/Instructions:**



## REBAR FABRICATION SPECIALISTS


Concrete Related Products LLC

Project: DPARD Admin Offices    Location: Dallas, TX    CRP Estimate#:

All materials shall be furnished in accordance with the recommended industry practice of the Concrete Reinforcing Institute and the C.R.S.I. Manual of Standard Practice unless otherwise described herein. All material will be new billet uncoated deformed reinforcing steel per A.S.T.M. Specification A615 (M) Grade 60 cut to length, bent, bundled and tagged, including detailed placing drawings per plans and specs.

Mill test reports (Certs) can be furnished in a reasonable amount of time after shipment of material, if required.

Respectfully Submitted



*Rodger Look* – CEO

For bending and placement of reinforcing, comply with ACI 315, "Details and Detailing of Concrete Reinforcement"

122 E. Industrial Blvd. Cleburne TX 76033

Mailing Address: PO BOX 436 Cleburne TX 76031

Office: (817)558-6999    Sales Fax: (817)558-9843